

NORTHAMPTON COUNTY



Building Department
P.O. 538
Eastville, VA 23347
Phone: (757) 678-0445
Fax: (757) 678-0483

Building Code - Design Criteria

Applicable Codes:	2009 Va. Uniform Statewide Building Code (Download: www.vbcoa.org) 2009 International Code Series 2008 NFPA 70 – National Electric Code
Design Wind Speed:	110 miles per hour
Wind Exposures:	B in towns, C elsewhere
Ground Snow Load:	10 pounds per square foot
Frost Line:	12 inches below final grade to bottom of the footing
Climate Zone / Heating Degree days:	IRC – Zone 8 / IECC – Zone 4 / Heating Degree Days Norfolk -3421
Earthquake / Seismic zone:	A
Virginia Architect / Engineer Seals Required:	When required by Code of Virginia Section 54.1-402; for construction within 1500 feet of tidal salt water; for structures over 3 stories in height; for unusual construction.

Local Amendment to USBC – Soils Policy: The State of Virginia has identified soils in the Northampton County area as potential shrink-swell soils. All footings must have a minimum of 2 runs of #4 or larger re-bar placed in the lower half of the footing. Footings wider than 16 inches must have one run of re-bar for every 8 inches (or portion thereof) of footing width. Persons wishing to place footings without re-bar must submit a report from a Va. Licensed soils engineer, stating that the footings are adequate to support the structure without re-bar, and that shrink-swell soils will not adversely affect the structure.